

KENYA MEDICAL SUPPLIES AUTHORITY

Commercial Street, Industrial Area
P.O. Box 47715, 00100 GPO,
Nairobi, Kenya



Tel: +254 20 3922000, Fax: +254 203922400
GSM +254 719 033000, +254 733 606600
Email: info@kemsa.co.ke

All Correspondence should be addressed to Chief Executive Officer

When replying please quote our ref:

Ref: GF-KEMSA- CONST-7/OIT6 /17 (1)

Date: 23rd November , 2017

CLARIFICATION 1:

Attn.: All Prospective Bidders

RE: TENDER NO. GF-KEMSA-CONST-7/OIT 6/2017-2018 FOR COLDROOM AND FREEZER INSTALLATIONS SPECIFICATIONS AND BILL OF QUANTITIES.

In accordance with ITT Clause 11.1 (Clarification of Tender Documents) of the Open International Tender (OIT) issued under the above reference, we hereby made clarifications as follows:

The Cold room and freezer room item no. A1.5, A2.5, C.5 and D5 in page 4, 8, 12 and 16 respectively of the BOQ, as **BOLDED** needs to be corrected.

Item	Description
A1.05	Package Condensing unit
A2.5	1) rating 12.9kw cooling Load
C.5	2) Refrigerant: R134A, R404, or 507
D.5	3) Voltage 415 V 50Hz complete with compressor, fan and all the accessories control and control panel as Carrier CRM 400-CY or Equal and approved

The corrected specifications are supposed to read as follows:

Item	Description
A1.05	Package Condensing unit
A2.5	1) rating 12.9kw cooling Load
C.5	2) Refrigerant: R134A, R404, or 507
D.5	3) Voltage 415 V 50Hz complete with compressor, fan and all the accessories control and control panel as Carrier CRL 900-DY or Equal and approved

Yours faithfully,


Charles E. Juma

Director, Procurement

FOR: Ag. CHIEF EXECUTIVE OFFICER

